

IZMERJENE VREDNOSTI POSAMEZNIH PARAMETROV 2024 - VS BUKOVO

PARAMETER	Normativ	DATUM VZORČENJA					
		6. 2.	25. 4.	12. 6.	21. 8.	1. 10.	14. 11.
Okus	≤ 1	0	0	brez	brez	1	brez
Temp. vode (°C)			10,4	14,6	19,5	16,2	12,0
pH	6,5 - 9,5	8,0	7,9	8,1	8,0	8,1	8,0
Elektr. prevodnost (μS/cm)	≤2500	253	321	255	264	251	249
Vonj	≤ 1	0	0	brez	brez	0	brez
Motnost (NTU)	≤ 4	<0,1	0			0,66	
E. coli (/100 ml)	0	0	0	0	0	0	0
Št. kolonj pri 22°C (/ml)	≤ 100	1	0	0	1	0	0
Št. kolonj pri 36°C (/ml)	≤ 100	4	1	0	0	0	1
Cl. perfringens (/100 ml)	0	0	0			0	
Enterokoki (/100 ml)	0	0	0	0	0	0	0
Koliformne bakterije (/100 ml)	0	0	0	0	0	0	0
Kalij (μg/l)		300					
Aluminij (μg/l)	200	0,93					
Kalcij (μg/l)		35000					
Magnezij (μg/l)		13000					
Amonij (mg/l)	0,5	<0,02					
Barva (/m)	≤ 0,5	<0,2					
Oksidativnost (mg/l)	5	<0,5					
Mangan (μg/l)	50	<0,1					
Natrij (mg/l)	200	1,1					
Klorid (mg/l)	250	1,9					
Skupna trdota (°N)		7,9					
Sulfat (mg/l)	250	7,5					

