

IZMERJENE VREDNOSTI POSAMEZNIH PARAMETROV 2024 - VS LAZEC

PARAMETER	Normativ	DATUM VZORČENJA					
		11. 1.	6. 2.	23. 4.	12. 6.	10. 7.	9. 10.
Okus	≤ 1		brez		brez	brez	1
Temp. vode (°C)		11,1		11,8	16,8	19,6	15,3
pH	6,5 - 9,5		8,0	7,9	8,1	8,0	8,0
Elektr. prevodnost (μS/cm)	≤2500		254	311	285	259	262
Vonj	≤ 1		brez		brez		1
Motnost (NTU)	≤ 4		<0,1	0,02			0,2
E. coli (/100 ml)	0		0	0	0	0	0
Št. kolonj pri 22°C (/ml)	≤ 100		0	1	4	1	0
Št. kolonj pri 36°C (/ml)	≤ 100		0	0	7	0	0
Cl. perfringens (/100 ml)	0		0	0			0
Enterokoki (/100 ml)	0		0	0	0		0
Koliformne bakterije (/100 ml)	0		0	0	1	0	0
Klor prosti (mg/l)	0,50	0,11		0,11	0,09	0,15	0,06
Trihalometani - vsota (μg/l)	≤ 100	4,5					
Barva (/m)	≤ 0,5		<0,2				
Amonij (mg/l)	≤ 0,5		<0,02				
Klorat (mg/l)	0,25			<0,05			
Klorit (mg/l)	0,25			<0,05			
Kalij (μg/l)			400				
Aluminij (μg/l)	200		16				
Kalcij (μg/l)			39000				
Magnezij (μg/l)			11000				
Oksidativnost (mg/l)	5		<0,5				
Mangan (μg/l)	50		<0,1				
Natrij (mg/l)	200		1,3				
Klorid (mg/l)	250		1,3				
Skupna trdota (°N)			8,0				
Sulfat (mg/l)	250		3,0				

